



2021/22 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	33	Region	Fraser Health
SD Name	Chilliwack	Contact Name	Barbara Haworth
SD Contact Name:	Allan Van Tass	Contact Phone	604-870-7920
SD Contact Phone:	604-762-6739	Report Submitted to HA	Yes
Report Date	13-May-22	Report Submission Date	13-May-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 17	0.001	No	N/A	Website	Class sink	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Kitchen	0.004	No	N/A	Website	Kitchen sink	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Water Fountain	Fountain 1 - corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Water Fountain	Fountain 2 - corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Water Fountain	Fountain 3 - corridor	0.000	No	N/A	Website	Fountain	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 1	0.001	No	N/A	Website	Kitchen sink (special Ed)	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 2	0.000	No	N/A	Website	Class sink	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 5	0.013	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Kindergarden sink - Bubbler sunroc	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 5	0.002	No	Replaced fountain with New Haws fountain (Re-Test results).	Website	Kindergarden sink - Bubbler sunroc	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 6	0.010	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 6	0.009	Yes	Replaced fountain with New Haws fountain.	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 6	0.000	No	Filter Added (Re-Test results) 1 m	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 7	0.008	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 7	0.035	Yes	Replaced fountain with New Haws fountain.	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 7	0.003	No	Filter Added (Re-Test results)	Website	Class sink - Bubbler Haws	Aug-22	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 10	0.003	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 11	0.001	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 12	0.002	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 13	0.002	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 14	0.002	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 15	0.002	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22
33	3333010	East Chilliwack	1981	Apr-22	1	Sink	Rm 16	0.003	No	N/A	Website	Storage Room Sink	Mar-25	30-Mar-22
33									-					30-Mar-22
33									-					30-Mar-22
33									-					30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Water Fountain	Fountain Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Staff Kitchen	0.001	No	N/A	Website	Kitchen sink	Mar-25	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
33	3333042	Greendale	2002	Apr-22	1	Sink	Kindergarten	0.005	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Haws Bubblers	Aug-22	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Kindergarten	0.010	Yes	New Bubler and braided lines installed	Website	Class sink - Haws Bubblers	Aug-22	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Kindergarten	0.000	No	Filter Added (Re-Test results) 1 m.	Website	Class sink - Haws Bubblers	Aug-22	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 11	0.001	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 12	0.001	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 13	0.001	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 14	0.003	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 15	0.001	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33	3333042	Greendale	2002	Apr-22	1	Sink	Rm 16	0.001	No	N/A	Website	Class sink - Haws Bubblers	Mar-25	30-Mar-22
33									-					30-Mar-22
33									-					30-Mar-22
33									-					30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 1	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 2	0.016	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 5	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 6	0.007	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 101	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 102	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 103	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 104	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 105	0.005	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 106	0.005	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 107	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 108	0.003	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 12	0.001	No	N/A	Website	Sink	Mar-25	30-Mar-22
33	3333030	F.G. Leary	1963	Apr-22	1	Sink	Rm 38	0.001	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22
33									-					
33									-					
33									-					
33									-					
33	3333011	Vedder El	1992	Apr-22	1	Sink	Library Sink	0.034	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class Sink		30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Staff Kitchen	0.001	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Multi Purpose	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	L/A Room	0.005	No	N/A	Website	Sink	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Kitchen (by Gym)	0.000	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Kitchen (by Rm 155)	0.001	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 140	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 141	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 160	0.006	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 161	0.008	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33									-					
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 162	0.000	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 164	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 165	0.009	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Bubblers	Aug-22	30-Mar-22
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 165	0.022	Yes	Bubbler replaced	Website	Class sink - Bubblers	Aug-22	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 165	0.000	No	Filter Added (Re Test Results) 1m.	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 168	0.009	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 168	0.005	Yes	Bubblers replaced	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 168	0.002	No	Filter Added (Re-Test Results).	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 169	0.007	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 142	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 147	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 148	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 149	0.014	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 149	0.008	Yes	Bubblers replaced	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 149	0.000	No	Filter Added (Re-Test Results) 1m.	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 151	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 152	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333011	Vedder El	1992	Apr-22	1	Sink	Rm 153	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33									-					30-Mar-22	
33									-					30-Mar-22	
33									-					30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 18	0.003	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 19	0.001	No	N/A	Website	Staff Kitcehn Sink		30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 21	0.048	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	L/A Class sink	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Kitchen	0.007	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Small Kitchen/canteen area	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Kitchen	0.004	No		Website	Small Kitchen/canteen area	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 23	0.010	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 24	0.005	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 25	0.009	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	kindergarten Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 27	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 28	0.003	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 29	0.003	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 30	0.008	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Special Ed class - sink	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 30	0.006	Yes	Fixture changed	Website	Special Ed class - sink	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 30	0.000	No	Filter Added (Re-Test Results).	Website	Special Ed class - sink	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 31	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Water Fountain	F4 - Corridor	0.000	No	N/A	Website	Corridor water fountain	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Corridor water fountain	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Water Fountain	F2 - Corridor	0.004	No	N/A	Website	Corridor water fountain	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Corridor water fountain	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 1	0.009	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 2	0.014	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 3	0.006	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 4	0.006	Yes	Bubblers removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 9	0.001	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 10	0.003	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 11	0.002	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 12	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Rm 6	0.004	No	N/A	Website	Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Library	0.060	Yes	Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Portable	0.007	Yes	Signage posted (Restricted use - Handwash Only)	Website	Hand Wash Sink	N/A	30-Mar-22	
33	3333019	Bernard El	1957	Apr-22	1	Sink	Portable	0.003	No	N/A	Website	Kitchen sink	Mar-25	30-Mar-22	
33									-						
33									-						
33									-						
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 120	0.005	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website		Aug-22	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 123	0.007	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	kindergarten Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 125	0.001	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 127	0.005	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	class sink - Bubblers	Aug-22	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 128	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 129	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 133	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 135	0.001	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 153	0.001	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 155	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 156	0.004	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 158	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Kindergarten Kitchen	0.003	No	N/A	Website	Kitchen sink	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Staff Kitchen	0.002	No	N/A	Website	Kitchen sink	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F3 - Corridor	0.003	No	N/A	Website	Fountain	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F4 - Corridor	0.003	No	N/A	Website	Fountain	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F5 - Corridor	0.000	No	N/A	Website	Fountain	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F6 - Corridor	0.000	No	N/A	Website	Fountain	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F7 - Corridor	0.087	Yes	Fixture removed	Website	Old Fountain	N/A	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Water Fountain	F8 - Corridor	0.009	Yes	Fixture removed	Website	Old Fountain	N/A	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 112	0.000	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 119	0.004	No	N/A	Website	kindergarten Class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Rm 166	0.002	No	N/A	Website	class sink - Bubblers	Mar-25	30-Mar-22	
33	3333003	Strathcona	1961	Apr-22	1	Sink	Kitchen Rm 134	0.001	No	N/A	Website	Kitchen Sink - Special Ed	Mar-25	30-Mar-22	
33									-					30-Mar-22	
33									-					30-Mar-22	
33									-					30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 118	0.002	No	N/A	Website	DayCare	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 410	0.010	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 310	0.019	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubblers	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 315-B	0.006	Yes	"Handwash only sign" placed	Website	Kitchen Sink	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 402	0.009	Yes	Room number wrong	Website	Class Sink - Bubblers	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 303	0.002	No	N/A	Website		Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 303-B	0.005	Yes	Signage posted (Restricted use - Handwash Only)	Website	Kitchen sink	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 308	0.004	No	N/A	Website	Class Sink - Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 309	0.001	No	N/A	Website	Class Sink - Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 309-B	0.004	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 311	0.002	No	N/A	Website	Class Sink Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 404	0.001	No	N/A	Website	Class Sink - Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 408	0.003	No	N/A	Website	Class Sink - Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 409	0.003	No	N/A	Website	Class Sink - Bubblers	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Water Fountain	F1 - Corridor	0.001	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 100-D	0.022	Yes	Signage posted (Restricted use - Handwash Only)	Website	First Aid Sink (Health Room)	Aug-22	30-Mar-22	

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 108	0.001	No	N/A	Website	Special Ed / Resourceclass - sink	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 114	0.001	No	N/A	Website	Kitchen Sink (Comm Serv)	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 316	0.019	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubbler	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 318	0.010	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class sink - Bubbler	Aug-22	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 305	0.003	No	N/A	Website	Class sink - Bubbler	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 411	0.002	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 419	0.004	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333015	Yarrow El	2012	Apr-22	1	Sink	Rm 421	0.002	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33								-	-					30-Mar-22	
33								-	-					30-Mar-22	
33								-	-					30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Water Fountain	F2 - Corridor	0.001	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Water Fountain	F4 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 100-E	0.001	No	N/A	Website	Health Room Sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 120	0.002	No	N/A	Website	Resouce room kitchen sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 141-A	0.001	No	N/A	Website	Prep room sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 143	0.003	No	N/A	Website	Foods Room sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 162 A	0.000	No	N/A	Website	Servery Kitchen sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 168	0.001	No	N/A	Website	Class sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 104	0.001	No	N/A	Website	Staff Kitcehn Sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 306	0.003	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 307	0.002	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 308	0.012	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class Sink - Bubbler	Aug-22	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 308	0.005	Yes	Bubblers removed and "hand wash only" signs placed.	Website	Class Sink - Bubbler	Aug-22	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 309	0.001	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 310	0.002	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 312	0.002	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 315	0.008	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing. 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 315	0.005	No	Replaced fountain with New Haws fountain.	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 173-A	0.002	No	N/A	Website	Wood Shop prep sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 145	0.001	No	N/A	Website	Art Room Sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 122	0.000	No	N/A	Website	Comm Serv (Kitchen sink)	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 138	0.001	No	N/A	Website	Daycare sink	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 305	0.001	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33	3333023	Rosedale El	2012	Apr-22	1	Sink	Rm 317	0.001	No	N/A	Website	Class Sink - Bubbler	Mar-25	30-Mar-22	
33								-	-						
33								-	-						
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F4 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22	

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN		ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F5 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F6 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F7 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F8 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F9 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Water Fountain	F10 - Corridor	0.000	No	N/A	Website	Elkay Fountain (filtered)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Office Health Rm	0.001	No	N/A	Website	Office First aid Health room sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Student Council	0.001	No	N/A	Website	Class sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1109	0.000	No	N/A	Website	Class sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	1003 Kitchen	0.000	No	N/A	Website	Kitchen sinks	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1121	0.006	Yes	Signage posted (Restricted use - Handwash Only)	Website	Hair salon sinks	Aug-22	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	AF-CAF	0.001	No	N/A	Website	Canteen sink (food prep)	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1172	0.002	No	N/A	Website	Kitchen class	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 2012	0.001	No	N/A	Website	Staff room Kitchen sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 3159	0.000	No	N/A	Website	Staff room Kitchen sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 2150	0.001	No	N/A	Website	Library sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1010	0.001	No	N/A	Website	Aborig Rm Sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1223	0.001	No	N/A	Website	Family Place sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1154	0.000	No	N/A	Website	Staff room Kitcehn Sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1000-F	0.001	No	N/A	Website	NLC Staff kitchen sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1164	0.001	No	N/A	Website	Resouce room kitchen sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 2159	0.000	No	N/A	Website	Weight Room Sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Rm 1166	0.000	No	N/A	Website	Resouce room kitchen sink	Mar-25	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Sick Room	0.005	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Health Room by Office	Aug-22	30-Mar-22
33	3333012	Chilliwack Secondary	2013	Apr-22	1	Sink	Sick Room	0.000	No	Re-Tested after remediation	Website	Health Room by Office	Aug-22	30-Mar-22
33									-					
33									-					
33									-					
33	3333005	Sardis El	1961	Apr-22	1	Sink	Kitchen 1	0.000	No	N/A	Website	Kitchen Sink	Mar-25	30-Mar-22

SCHOOL FACILITY INFORMATION				TEST INFORMATION						MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Kindergarten Kitchen	0.001	No	N/A	Website	Kindergarten Kitchen Sink	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Staff Kitchen	0.000	No	N/A	Website	Staff Room Kitchen sink	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Library Office	0.004	No	N/A	Website	Library sink	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Water Fountain	F1 - Corridor	0.000	No	N/A	Website	Hall Drinking fountains	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Water Fountain	F2 - Corridor	0.000	No	N/A	Website	Hall Drinking fountains	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Water Fountain	F3 - Corridor	0.000	No	N/A	Website	Hall Drinking fountains	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 2	0.003	No	N/A	Website	Class Sink (Kindergarten)- Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 3	0.001	No	N/A	Website	Class Sink (Kindergarten)- Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 7	0.001	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 8	0.001	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 10	0.001	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 43	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 44	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 45	0.001	No	N/A	Website	Class Sink (Multi Purpose)- Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 22	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 23	0.010	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class Sink - Bubbler was bagged(Covid)	Aug-22	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 23	0.010	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class Sink - Bubbler was bagged(Covid)	Aug-22	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 24	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 25	0.068	Yes	1-Remove fixture and add sign ("hand wash only") if not needed for drinking use. 2-Plumbing feed line to be checked and replaced if outdated and lead containing 3-Replace fixture if lead containing. 4-Re -Test and add filter if levels don't meet requirements.	Website	Class Sink - Bubbler was bagged(Covid)	Aug-22	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 25	0.008	Yes	Bubbler removed, Signage posted (Restricted use - Handwash Only)	Website	Class Sink - Bubbler was bagged(Covid)	Aug-22	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 26	0.001	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 27	0.004	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 11	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	
33	3333005	Sardis EI	1961	Apr-22	1	Sink	Rm 12	0.002	No	N/A	Website	Class Sink - Bubbler was bagged(Covid)	Mar-25	30-Mar-22	