

School Identifier	Testing information						Result				
Ministry Asset Number	Test Date (dd-mm-yyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration	Mitigation Strategy Selected	Public Communication Plan	
123456	11-12-2022	07:45:00	11_1_104_Cf	Flushed	CF	Classroom Faucet (CF) in room 104, first floor, facility 211.	0.0043	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.	
AD.Rundle								-		-	
								-		-	
	102080	31-01-2026	14:00:00	KC 4A	Flushed	KC	Staff Room (Room 4)	0.00265	No		-
	102080	31-01-2026	14:05:00	KC 4B	First Draw	KC	Staff Room (Room 4)	0.00548	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102080	19-07-2026	06:00:00	KC4B	First Draw	KC	Staff Room (Room 4)	0.0003	No		Re Test Results
	102080	31-01-2026	14:10:00	NS 26A	Flushed	NS	First Aid Room (Room 26)	0.00417	No		-
	102080	31-01-2026	14:15:00	NS 26B	First Draw	NS	First Aid Room (Room 26)	0.0101	Yes	3C	Restrict access to fixture. Post signage or remove.
	102080	31-01-2026	14:20:00	BM 4	First Draw	BM	Staff Room (Room 4) coffie maker	0.00082	No		-
	102080	31-01-2026	14:25:00	BF17	First Draw	BS	North Corridor (C30) Bottle Filler	0.00001	No		-
	102080	31-01-2026	14:30:00	DW 17	First Draw	DW	North Corridor (C30) Drinking Fountain	0.00001	No		-
	102080	31-01-2026	14:35:00	1KC 92A	Flushed	KC	Cafeteria Concession Kitchen Faucet	0.00301	No		-
	102080	31-01-2026	14:40:00	1KC 92B	First Draw	KC	Cafeteria Concession Kitchen Faucet	0.0157	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102080	19-07-2026	06:10:00	1KC 92B	First Draw	KC	Cafeteria Concession Kitchen Faucet	0.00078	No		Re Test Results
	102080	31-01-2026	14:45:00	2KC 92A	First Draw	KC	Cafeteria Concession Kitchen Faucet	0.0108	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102080	31-01-2026	14:50:00	2KC 92B	Flushed	KC	Cafeteria Concession Kitchen Faucet	0.00129	No		
	102080	19-07-2026	00:00:00	2KC 92A	First Draw	KC	Cafeteria Concession Kitchen Faucet	0.00957	Yes		To be replaced and filter added
										Restrict access to fixture by posting signage or remove completely. Inform management, regional public health office, and water supplier.	
	102080	31-01-2026	14:55:00	1KC 24A	First Draw	KC	Room 24 Kitchen Faucet	0.0198	Yes	4E	
										Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.	
										Restrict access to fixture by posting signage or remove completely. Inform management, regional public health office, and water supplier.	
	102080	31-01-2026	15:00:00	1KC 24B	Flushed	KC	Room 24 Kitchen Faucet	0.012	Yes	4E	
										Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended.	
	102080	19-07-2026	06:40:00	1KC 24B	First Draw	KC	Room 24 Kitchen Faucet	0.00073	No		Re Test Results
	102080	31-01-2026	15:05:00	2KC24A	Flushed	KC	Room 24 Kitchen Faucet	0.00312	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102080	31-01-2026	15:10:00	2KC24B	First Draw	KC	Room 24 Kitchen Faucet	0.00838	Yes		
	102080	19-07-2026	06:50:00	2KC24B	First Draw	KC	Room 24 Kitchen Faucet	0.0009	No		Re Test Results
102080	31-01-2026	15:15:00	DW 33	First Draw	DW	Central Coridor (C50) Drinking Fountain	0.00213	No		-	
102080	31-01-2026	15:20:00	1KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #1	0.0522	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.	
102080	31-01-2026	15:25:00	1KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #1	0	No		-	
102080	19-07-2026	07:00:00	1KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #2	0.00239	No		Re Test Results	
102080	31-01-2026	15:30:00	2KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #2	0.00276	No		-	
102080	31-01-2026	15:35:00	2KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #2	0.00311	No		-	
102080	31-01-2026	15:40:00	3KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #3	0.00336	No		-	
102080	31-01-2026	15:45:00	3KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #3	0.00281	No		-	
102080	31-01-2026	15:50:00	4KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #4	0.00316	No		-	
102080	31-01-2026	15:55:00	4KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #4	0.0032	No		-	
102080	31-01-2026	16:00:00	5KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #5	0.00256	No		-	
102080	31-01-2026	16:05:00	5KC 202B	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #5	0.00094	No		-	
102080	31-01-2026	16:10:00	6KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #6	0.00299	No		-	
102080	31-01-2026	16:15:00	6KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #6	0.00101	No		-	
102080	31-01-2026	16:20:00	7KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #7	0.00958	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.	
102080	31-01-2026	16:25:00	7KC 202B	Flushed	KC	Foods Room (Rom 202) Kitchen Faucet #7	0.00077	No		-	
102080	19-07-2026	07:10:00	7KC 202A	First Draw	KC	Foods Room (Rom 202) Kitchen Faucet #8	0.00077	No		Re Test Results	
102080	31-01-2026	16:30:00	BF 201	First Draw	BS	West Corridor (C60) Bottle Filler	0.0001	No		-	
102080	31-01-2026	16:35:00	DW 201	First Draw	DW	West Corridor (C60) Drinking Fountain	0.0001	No		-	
102080	31-01-2026	16:40:00	KC 208A	First Draw	KC	Resource Room (Room 208) Kitchen Faucet	0.00467	No		-	
102080	31-01-2026	16:45:00	KC 208B	Flushed	KC	Resource Room (Room 208) Kitchen Faucet	0.00152	No		-	
102080	31-01-2026	16:50:00	KC 111A	First Draw	KC	Library prep (Room 109) Kitchen Faucet	0.00095	No		-	
102080	31-01-2026	16:55:00	KC 111B	Flushed	KC	Library prep (Room 109) Kitchen Faucet	0.00092	No		-	
102080	31-01-2026	17:00:00	BF 34	First Draw	BS	East Coridor (C90) Bottle Filler	0.0001	No		-	
102080	31-01-2026	17:05:00	DW 34	First Draw	BS	East Coridor (C90) Drinking Fountain	0.0001	No		-	
102080	31-01-2026	17:10:00	DW 97	First Draw	DW	Wood Shop Rm 97 Bubbler	0.00921	Yes	3C	Restrict access to fixture. Post signage or remove.	
								-		-	
								-		-	
								-		-	
								-		-	
Central EI											
	101996	01-02-2026	07:30:00	KC 122A	First Draw	KC	Kitchen Faucet (Cafeteria Room 122)	0.00719	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	101996	01-02-2026	07:35:00	KC 122B	Flushed	KC	Kitchen Faucet (Cafeteria Room 122)	0.00461	No		-

101996	19-07-2026	08:00:00	KC 122A	First Draw	KC	Kitchen Faucet (Cafeteria Room 122)	0.00097	No		Re Test Results
101996	01-02-2026	07:40:00	KC 125A	First Draw	KC	Kitchen Faucet (Multi-purpose Room 125)	0.0213	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	07:45:00	KC 125B	Flushed	KC	Kitchen Faucet (Multi-purpose Room 125)	0.00041	No		
101996	01-02-2026	07:50:00	KC 125DA	First Draw	KC	Kitchen Faucet (Multi-purpose Room 125)	0.00132	No		-
101996	01-02-2026	07:55:00	KC 125DB	Flushed	KC	Kitchen Faucet (Multi-purpose Room 125)	0.0001	No		-
101996	01-02-2026	08:00:00	BF 121	First Draw	BS	Bottle Filler (Corridor Lower Floor North)	0.0001	No		-
101996	01-02-2026	08:05:00	DW 121	First Draw	DW	Drinking Fountain (Corridor Lower Floor North)	0.0001	No		-
101996	01-02-2026	08:10:00	KC 118A	First Draw	KC	Kitchen Faucet Prep (Room 118)	0.0236	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
101996	01-02-2026	08:15:00	KC 118B	Flushed	KC	Kitchen Faucet Prep (Room 118)	0.0002	No		-
101996	19-07-2026	08:10:00	KC 118A	First Draw	KC	Kitchen Faucet Prep (Room 118)	0.0015	No		Re Test Results
101996	01-02-2026	08:20:00	KC 117A	First Draw	KC	Kitchen Faucet (Room 117)	0.00209	No		-
101996	01-02-2026	08:25:00	KC 117B	Flushed	KC	Kitchen Faucet (Room 117)	0.0005	No		-
101996	01-02-2026	08:30:00	BF 101	First Draw	BS	Bottle Filler (Corridor Lower Floor South)	0.0001	No		-
101996	01-02-2026	08:35:00	DW 101	First Draw	DW	Drinking Fountain (Corridor Lower Floor South)	0.0001	No		-
101996	01-02-2026	08:40:00	KC 101A	First Draw	KC	Kitchen Faucet (Room 101)	0.00118	No		-
101996	01-02-2026	08:45:00	KC 11B	First Draw	KC	Kitchen Faucet (Room 101)	0.00088	No		-
101996	01-02-2026	08:50:00	DW 201	First Draw	DW	Drinking Fountain (Corridor 2nd Floor South)	0.00384	No		-
101996	01-02-2026	08:55:00	KC 201A	First Draw	KC	Kitchen Faucet (Lib Office Room 201)	0.00526	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	09:00:00	KC 201B	Flushed	KC	Kitchen Faucet (Lib Office Room 201)	0.00035	No		-
101996	01-02-2026	09:05:00	NS 207A	First Draw	NS	First Aid Room (Room 207)	0.00084	No		-
101996	01-02-2026	09:10:00	NS 207B	Flushed	NS	First Aid Room (Room 207)	0.00024	No		-
101996	01-02-2026	09:15:00	CF 209A	First Draw	CF	Classroom Faucet (Room 209)	0.0017	No		-
101996	01-02-2026	09:20:00	CF 209B	Flushed	CF	Classroom Faucet (Room 209)	0.0001	No		-
101996	01-02-2026	09:25:00	CF 210A	First Draw	CF	Classroom Faucet (Room 210)	0.00687	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	09:30:00	CF 210B	Flushed	CF	Classroom Faucet (Room 210)	0.00086	No		-
101996	01-02-2026	09:35:00	1CF 211A	First Draw	CF	K Classroom Faucet (Room 211)	0.0024	No		-
101996	01-02-2026	09:40:00	1CF 211B	Flushed	CF	K Classroom Faucet (Room 211)	0.0003	No		-
101996	01-02-2026	09:45:00	2CF 211A	First Draw	CF	K Classroom Faucet (Room 211)	0.00524	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	09:50:00	2CF 211B	Flushed	CF	K Classroom Faucet (Room 211)	0.00056	No		-
101996	01-02-2026	09:55:00	CF 212A	First Draw	CF	Classroom Faucet (Room 209)	0.0119	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	10:00:00	CF 212B	Flushed	CF	Classroom Faucet (Room 209)	0.00087	No		
101996	01-02-2026	10:05:00	KC 213A	First Draw	KC	Kitchen Faucet (Room 213-small Kitchen)	0.00172	No		-
101996	01-02-2026	10:10:00	KC 213B	Flushed	KC	Kitchen Faucet (Room 213-small Kitchen)	0.00124	No		-
101996	01-02-2026	10:15:00	BF 213	First Draw	BS	Bottle Filler (Corridor 2nd Floor Gym)	0.0001	No		-
101996	01-02-2026	10:20:00	DW 213	First Draw	DW	Drinking Fountain (Corridor 2nd Floor Gym)	0.0001	No		-
101996	01-02-2026	10:25:00	CF 301A	First Draw	CF	Classroom Faucet (Room 301)	0.0183	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	10:30:00	CF 301B	First Draw	CF	Classroom Faucet (Room 301)	0.0004	No		
101996	01-02-2026	10:35:00	CF 302A	First Draw	CF	Classroom Faucet (Room 302)	0.00049	No		-
101996	01-02-2026	10:40:00	CF 302B	Flushed	CF	Classroom Faucet (Room 302)	0.00037	No		-
101996	01-02-2026	10:45:00	CF 303A	First Draw	CF	Classroom Faucet (Room 303)	0.00121	No		-
101996	01-02-2026	10:50:00	CF 303B	Flushed	CF	Classroom Faucet (Room 303)	0.00057	No		-
101996	01-02-2026	10:55:00	CF 304A	First Draw	CF	Classroom Faucet (Room 304)	0.00312	No		-
101996	01-02-2026	11:00:00	CF 304B	Flushed	CF	Classroom Faucet (Room 304)	0.00022	No		-
101996	01-02-2026	11:05:00	KC 307A	First Draw	KC	Kitchen Faucet (Room 307 - Staff Room)	0.00325	No		-
101996	01-02-2026	11:10:00	KC 307B	Flushed	KC	Kitchen Faucet (Room 307 - Staff Room)	0.00025	No		-
101996	01-02-2026	11:15:00	CF 309A	First Draw	CF	Classroom Faucet (Room 309)	0.000634	No		-
101996	01-02-2026	11:20:00	CF 309B	Flushed	CF	Classroom Faucet (Room 309)	0.00348	No		-
101996	01-02-2026	11:25:00	BF 309	First Draw	BS	Bottle Filler (Corridor 3rd Floor)	0.0001	No		-
101996	01-02-2026	11:30:00	DW 309	First Draw	DW	Drinking Fountain (Corridor 3rd Floor)	0.00055	No		-
101996	01-02-2026	11:35:00	CF 310A	First Draw	CF	Classroom Faucet (Room 310)	0.0104	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	11:40:00	CF 310B	Flushed	CF	Classroom Faucet (Room 310)	0.00228	No		
101996	01-02-2026	11:45:00	CF 311A	First Draw	CF	Classroom Faucet (Room 311)	0.00549	Yes	3C	Restrict access to fixture. Post signage or remove.
101996	01-02-2026	11:50:00	CF 311B	Flushed	CF	Classroom Faucet (Room 311)	0.00121	No		
101996	01-02-2026	11:55:00	CF 312A	First Draw	CF	Classroom Faucet (Room 312)	0.00404	No		-
101996	01-02-2026	12:00:00	CF 312B	First Draw	CF	Classroom Faucet (Room 312)	0.00101	No		-
							-	-		-
Cheam Elementary										-
102017	01-02-2026	12:45:00	KC 14A	First Draw	KC	Staff Room Kitchen Sink (Room 14)	0.00036	No		-
102017	01-02-2026	12:50:00	KC14B	Flushed	KC	Staff Room Kitchen Sink (Room 14)	0.00027	No		-
102017	01-02-2026	12:55:00	BF 4	First Draw	BS	Bottle Filler (Main Corridor)	0.0001	No		-
102017	01-02-2026	13:00:00	DW 4	First Draw	DW	Drinking Fountain (Main Corridor)	0.0001	No		-
102017	01-02-2026	13:05:00	KC 10A	First Draw	KC	Libbray prep Room Sink (Room 10)	0.0117	Yes	3C	Restrict access to fixture. Post signage or remove.
102017	01-02-2026	13:10:00	KC 10B	Flushed	KC	Libbray prep Room Sink (Room 10)	0.00042	No		
102017	01-02-2026	13:15:00	BF 30	First Draw	BF	Bottle Filler (Gym)	0.0001	No		-
102017	01-02-2026	13:20:00	DW 30	Flushed	DW	Drinking Fountain (Gym)	0.0001	No		-
							-	-		-
Kwiyeqel South (Chance)										-
102057	01-02-2026	12:15:00	KC A	First Draw	KC	Site Kitchen Sink Faucet	0.0115	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
102057	01-02-2026	12:20:00	KC B	Flushed	KC	Site Kitchen Sink Faucet	0.00036	No		-
102057	19-07-2026	08:30:00	KC A	First Draw	KC	Site Kitchen Sink Faucet	0.00032	No		Re Test Results
102057	01-02-2026	12:25:00	BF	First Draw	BS	Bottle Filler (Main Corridor)	0.00027	No		-

102057	01-02-2026	12:30:00	DW	First Draw	DW	Drinking Fountain (Main Corridor)	0.00038	No	-		
McCammon EI								-	-		
								-	-		
	102075	31-01-2026	08:00:00	KC 9A	First Draw	KC	Staff Room Kitchen Sink (Room 9)	0.0339	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102075	31-01-2026	08:05:00	KC 9B	Flushed	KC	Staff Room Kitchen Sink (Room 9)	0.00048	No	-	
102075	19-07-2026	07:40:00	KC 9A	First Draw	KC	Staff Room Kitchen Sink (Room 9)	0.00199	No	Re Test Results		
102075	31-01-2026	08:10:00	BF 4	First Draw	BS	Bottle Filler (Gym Corridor)	0.0001	No	-		
102075	31-01-2026	08:15:00	DW 4	First Draw	DW	Drinking Fountain (Gym Corridor)	0.0001	No	-		
102075	31-01-2026	08:20:00	KC 34A	First Draw	KC	Gym Kitchen	0.00075	No	-		
102075	31-01-2026	08:25:00	KC 34B	Flushed	KC	Gym Kitchen	0.0001	No	-		
102075	31-01-2026	08:30:00	CF 8A	First Draw	CF	Classroom Faucet (Room 8)	0.0634	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	08:35:00	CF 8B	Flushed	CF	Classroom Faucet (Room 8)	0.0233	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	08:40:00	CF 10A	First Draw	CF	Classroom Faucet (Room 10)	0.0061	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	08:45:00	CF 10B	Flushed	CF	Classroom Faucet (Room 10)	0.00138	No	-		
102075	31-01-2026	08:50:00	CF 12A	First Draw	CF	Classroom Faucet (Room 12)	0.56	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	08:55:00	CF 12B	Flushed	CF	Classroom Faucet (Room 12)	0.0004	No	-		
102075	31-01-2026	09:00:00	NS 46A	First Draw	NS	First Aid Room (Room 46)	0.00183	No	-		
102075	31-01-2026	09:05:00	NS 46B	Flushed	NS	First Aid Room (Room 46)	0.00026	No	-		
102075	31-01-2026	09:10:00	KC 14A	First Draw	KC	Multipurpose Kitchen Faucet (Room 14)	0.00051	No	-		
102075	31-01-2026	09:15:00	KC 14B	Flushed	KC	Multipurpose Kitchen Faucet (Room 14)	0.00023	No	-		
102075	31-01-2026	09:20:00	KC 52A	First Draw	KC	Libbray prep Room Faucet (Room 52)	0.00149	No	-		
102075	31-01-2026	09:25:00	KC 52B	Flushed	KC	Libbray prep Room Faucet (Room 52)	0.00099	No	-		
102075	31-01-2026	09:30:00	BF 14	First Draw	BS	Bottle Filler (East Corridor)	0.0001	No	-		
102075	31-01-2026	09:35:00	DW 14	First Draw	DW	Drinking Fountain (East Corridor)	0.0001	No	-		
102075	31-01-2026	09:40:00	CF 16A	First Draw	CF	Classroom Faucet (Room 16)	0.0173	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	09:45:00	CF 16B	Flushed	CF	Classroom Faucet (Room 16)	0.00599	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	09:50:00	CF 18A	First Draw	CF	Classroom Faucet (Room 18)	0.00381	No	-		
102075	31-01-2026	09:55:00	CF 18B	Flushed	CF	Classroom Faucet (Room 18)	0.00078	No	-		
102075	31-01-2026	10:00:00	KC 19A	First Draw	KC	Classroom Kitchen Faucet (Room 19)	0.00848	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.	
102075	31-01-2026	10:05:00	KC 19B	Flushed	KC	K Classroom Kitchen Faucet (Room 19)	0.00276	No	-		
102075	19-07-2026	07:50:00	KC 19A	First Draw	KC	K Classroom Kitchen Faucet (Room 19)	0.00074	No	Re Test Results		
102075	31-01-2026	10:10:00	KC 17A	First Draw	KC	K Classroom Kitchen Faucet (Room 17)	0.0529	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	10:15:00	KC 17B	Flushed	KC	K Classroom Kitchen Faucet (Room 17)	0.00033	No	-		
102075	31-01-2026	10:20:00	CF 21A	First Draw	CF	Classroom Faucet (Room 21)	0.00556	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	10:25:00	CF 21B	Flushed	CF	Classroom Faucet (Room 21)	0.00039	No	-		
102075	31-01-2026	10:30:00	CF 23A	First Draw	CF	Classroom Faucet (Room 23)	0.00347	No	-		
102075	31-01-2026	10:35:00	CF 23B	Flushed	CF	Classroom Faucet (Room 23)	0.00044	No	-		
102075	31-01-2026	10:40:00	CF 24A	First Draw	CF	Classroom Faucet (Room 24)	0.00132	No	-		
102075	31-01-2026	10:45:00	CF 24B	Flushed	CF	Classroom Faucet (Room 24)	0.00024	No	-		
102075	31-01-2026	10:50:00	CF 26A	First Draw	CF	Classroom Faucet (Room 26)	0.0253	Yes	-		
102075	31-01-2026	10:55:00	CF 26B	Flushed	CF	Classroom Faucet (Room 26)	0.00122	No	-		
102075	31-01-2026	11:00:00	BF 27	First Draw	BS	Bottle Filler (West Corridor)	0.0001	No	-		
102075	31-01-2026	11:05:00	DW 27	First Draw	DW	Drinking Fountain (West Corridor)	0.0001	No	-		
102075	31-01-2026	11:10:00	CF 27A	First Draw	CF	Classroom Faucet (Room 27)	0.00932	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	11:15:00	CF 27B	Flushed	CF	Classroom Faucet (Room 27)	0.00028	No	-		
102075	31-01-2026	11:20:00	CF 28A	First Draw	CF	Classroom Faucet (Room 28)	0.00036	No	-		
102075	31-01-2026	11:25:00	CF 28B	Flushed	CF	Classroom Faucet (Room 28)	0.00323	No	-		
102075	31-01-2026	11:30:00	CF 29A	First Draw	CF	Classroom Faucet (Room 29)	0.00399	No	-		
102075	31-01-2026	11:35:00	CF 29B	Flushed	CF	Classroom Faucet (Room 29)	0.0076	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	11:40:00	CF 30A	First Draw	CF	Classroom Faucet (Room 30)	0.00563	Yes	3C	Restrict access to fixture. Post signage or remove.	
102075	31-01-2026	11:45:00	CF 30B	Flushed	CF	Classroom Faucet (Room 30)	0.00083	No	-		
102075	31-01-2026	11:50:00	KC 4A	First Draw	KC	Kitchen classroom Faucet (Room 4)	0.00083	No	-		
102075	31-01-2026	11:55:00	KC 4B	Flushed	KC	Kitchen classroom Faucet (Room 4)	0.00053	No	-		
102075	31-01-2026	12:00:00	CF 3A	First Draw	CF	Classroom Faucet (Room 3)	0.00341	No	-		
102075	31-01-2026	12:05:00	CF 3B	Flushed	CF	Classroom Faucet (Room 3)	0.00021	No	-		
102075	31-01-2026	12:10:00	BF 4	First Draw	BS	Bottle Filler (Gym Corridor)	0.0001	No	-		
102075	31-01-2026	12:15:00	DW 4	First Draw	DW	Drinking Fountain (Gym Corridor)	0.0001	No	-		
102075	31-01-2026	12:20:00	CF 2A	First Draw	CF	Classroom Faucet (Room 2)	0.00067	No	-		
102075	31-01-2026	12:25:00	CF 2B	Flushed	CF	Classroom Faucet (Room 2)	0.0001	No	-		
Mount Slesse								-	-		
								-	-		
	120427	08-02-2026	07:00:00	KC N137A	First Draw	KC	Staff Room Kitchen Faucet (Room N137)	0.00149	No	-	
	120427	08-02-2026	07:05:00	KC N137B	Flushed	KC	Staff Room Kitchen Faucet (Room N137)	0.00034	No	-	
	120427	08-02-2026	07:10:00	KI 137	First Draw	KI	Staff Room Kitchen Ice (Room N137)	0.00059	No	-	
	120427	08-02-2026	07:15:00	NS N143	First Draw	NS	Health Room Faucet (Room N143)	0.0016	No	-	
	120427	08-02-2026	07:20:00	KC N134A	First Draw	KC	Kitchen Faucet Canteen (Room N134)	0.00082	No	-	
	120427	08-02-2026	07:25:00	KC N134B	Flushed	KC	Kitchen Faucet Canteen (Room N134)	0.0001	No	-	
	120427	08-02-2026	07:30:00	KC N170A	First Draw	KC	Kitchen Faucet Custodial (Room N170A)	0.00186	No	-	
	120427	08-02-2026	07:35:00	KC N170B	Flushed	KC	Kitchen Faucet Custodial (Room N170A)	0.0001	No	-	
	120427	08-02-2026	07:40:00	1KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.00065	No	-	
	120427	08-02-2026	07:45:00	1KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.00029	No	-	

120427	08-02-2026	07:50:00	2KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.00034	No	-	
120427	08-02-2026	07:55:00	2KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.00027	No	-	
120427	08-02-2026	08:00:00	3KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.0001	No	-	
120427	08-02-2026	08:05:00	3KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.00162	No	-	
120427	08-02-2026	08:10:00	4KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.00037	No	-	
120427	08-02-2026	08:15:00	4KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.0001	No	-	
120427	08-02-2026	08:20:00	5KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.0001	No	-	
120427	08-02-2026	08:25:00	5KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.00042	No	-	
120427	08-02-2026	08:30:00	6KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.0005	No	-	
120427	08-02-2026	08:35:00	6KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.0001	No	-	
120427	08-02-2026	08:40:00	7KC N150A	First Draw	KC	Kitchen Faucet Foods (Room CN150)	0.00156	No	-	
120427	08-02-2026	08:45:00	7KC N150B	Flushed	KC	Kitchen Faucet Foods (Room CN150)	0.0001	No	-	
120427	08-02-2026	08:50:00	KC N145A	First Draw	KC	Kitchen Faucet (Room N145)	0.00021	No	-	
120427	08-02-2026	08:55:00	KC N145B	Flushed	KC	Kitchen Faucet (Room N145)	0.0001	No	-	
120427	08-02-2026	09:00:00	KC N146A	First Draw	KC	Kitchen Faucet (Room N146)	0.00818	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
120427	08-02-2026	09:05:00	KC N146B	Flushed	KC	Kitchen Faucet (Room N146)	0.00024	No	-	
120427	19-07-2026	09:30:00	KC N146A	First Draw	KC	Kitchen Faucet (Room N146)	0.00086	No		Re Test Results
120427	08-02-2026	09:10:00	BF N118	First Draw	BS	Bottle Filler (North gym Corridor)	0.0001	No	-	
120427	08-02-2026	09:15:00	DW N118	First Draw	DW	Drinking Fountain (North gym Corridor)	0.0001	No	-	
120427	08-02-2026	09:20:00	KC S101A	First Draw	KC	Kitchen Faucet (Room S101 - Lib Office)	0.00058	No	-	
120427	08-02-2026	09:25:00	KC S101B	Flushed	KC	Kitchen Faucet (Room S101 - Lib Office)	0.0001	No	-	
120427	08-02-2026	09:30:00	BF W107	First Draw	BS	Bottle Filler (West Corridor)	0.0001	No	-	
120427	08-02-2026	09:35:00	DW W107	First Draw	DW	Drinking Fountain (West Corridor)	0.0001	No	-	
120427	08-02-2026	09:40:00	1DW W122	First Draw	DW	Drinking Fountain (West Corridor)	0.0008	No	-	
120427	08-02-2026	09:45:00	2DW W122	First Draw	DW	Drinking Fountain (West Corridor)	0.00234	No	-	
120427	08-02-2026	09:50:00	KC W124A	First Draw	KC	Kitchen Faucet (Room W124)	0.00081	No	-	
120427	08-02-2026	09:55:00	KC W124B	Flushed	KC	Kitchen Faucet (Room W124)	0.00071	No	-	
120427	08-02-2026	10:00:00	KC S123A	First Draw	KC	Kithcen Faucet (Room S123)	0.00301	No	-	
120427	08-02-2026	10:05:00	KC S123B	Flushed	KC	Kithcen Faucet (Room S123)	0.00818	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
120427	19-07-2026	09:40:00	KC S123B	First Draw	KC	Kithcen Faucet (Room S123)	0.00025	No		Re Test Results
120427	08-02-2026	10:10:00	BF S123	First Draw	BS	Bottle Filler (South Corridor)	0.0001	No	-	
120427	08-02-2026	10:15:00	DW S123	First Draw	DW	Drinking Fountain (South Corridor)	0.0001	No	-	
120427	08-02-2026	10:20:00	KC S223A	First Draw	KC	Kithcen Faucet (Room S223)	0.00094	No	-	
120427	08-02-2026	10:25:00	KC S223B	Flushed	KC	Kithcen Faucet (Room S223)	0.00558	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
120427	19-07-2026	09:50:00	KC S223B	First Draw	KC	Kithcen Faucet (Room S223)	0.00023	No		Re Test Results
120427	08-02-2026	10:30:00	BF S223	First Draw	BS	Bottle Filler (2nd Floor Corridor)	0.0001	No	-	
120427	08-02-2026	10:35:00	DW S223	First Draw	DW	Drinking Fountain (2nd Floor Corridor)	0.0001	No	-	
South Side Elementary Middle (Stitos)								-	-	
400008	16-02-2026	07:00:00	KC 1060A	First Draw	KC	Staff Room Kitchen Faucet (Room 1060)	0.0006	No	-	
400008	16-02-2026	07:05:00	KC 1060B	Flushed	KC	Staff Room Kitchen Faucet (Room 1060)	0.0001	No	-	
400008	16-02-2026	07:10:00	NS 1057A	First Draw	NS	First Aid (Room 1057)	0.00329	No	-	
400008	16-02-2026	07:15:00	NS 1057B	Flushed	NS	First Aid (Room 1057)	0.00034	No	-	
400008	16-02-2026	07:20:00	KC 1082A	First Draw	KC	K Classroom Faucet (Room 1082)	0.00053	No	-	
400008	16-02-2026	07:25:00	KC 1082B	Flushed	KC	K Classroom Faucet (Room 1082)	0.0001	No	-	
400008	16-02-2026	07:30:00	KC 1086A	First Draw	KC	K Classroom Faucet (Room 1086)	0.00079	No	-	
400008	16-02-2026	07:35:00	KC 1086B	Flushed	KC	K Classroom Faucet (Room 1086)	0.0001	No	-	
400008	16-02-2026	07:40:00	KC 1102A	First Draw	KC	B/A Classroom Faucet (Room 1102)	0.00032	No	-	
400008	16-02-2026	07:45:00	KC 1102B	Flushed	KC	B/A Classroom Faucet (Room 1102)	0.0001	No	-	
400008	16-02-2026	07:50:00	KC 1104A	First Draw	KC	B/A Classroom Faucet (Room 1104)	0.00169	No	-	
400008	16-02-2026	07:55:00	KC 1104B	Flushed	KC	B/A Classroom Faucet (Room 1104)	0.0001	No	-	
400008	16-02-2026	08:00:00	KC 1108A	First Draw	KC	Classroom Prep Room Faucet (Room 1108)	0.00112	No	-	
400008	16-02-2026	08:05:00	KC 1108B	Flushed	KC	Classroom Prep Room Faucet (Room 1108)	0.0001	No	-	
400008	16-02-2026	08:10:00	BF 1108	First Draw	BS	Bottle Filler	0.0001	No	-	
400008	16-02-2026	08:15:00	DW 1108	First Draw	DW	Drinking Fountain	0.0001	No	-	
400008	16-02-2026	08:20:00	1KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00061	No	-	
400008	16-02-2026	08:25:00	1KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.00028	No	-	
400008	16-02-2026	08:30:00	2KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00087	No	-	
400008	16-02-2026	08:35:00	2KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.00033	No	-	
400008	16-02-2026	08:40:00	3KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00077	No	-	
400008	16-02-2026	08:45:00	3KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.0029	No	-	
400008	16-02-2026	08:50:00	4KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00049	No	-	
400008	16-02-2026	08:55:00	4KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.0003	No	-	
400008	16-02-2026	09:00:00	5KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00063	No	-	
400008	16-02-2026	09:05:00	5KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.00032	No	-	
400008	16-02-2026	09:10:00	6KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00056	No	-	
400008	16-02-2026	09:15:00	6KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.0001	No	-	
400008	16-02-2026	09:20:00	7KC 1007A	First Draw	KC	Kitchen Faucet (Home Ec Room 1007)	0.00227	No	-	
400008	16-02-2026	09:25:00	7KC 1007B	Flushed	KC	Kitchen Faucet (Home Ec Room 1007)	0.00029	No	-	
400008	16-02-2026	09:30:00	KC 1015A	First Draw	KC	Kitchen Faucet (Serv Room 1015)	0.00062	No	-	
400008	16-02-2026	09:35:00	KC 1015B	Flushed	KC	Kitchen Faucet (Serv Room 1015)	0.0001	No	-	

	400008	16-02-2026	09:40:00	KC 1130A	First Draw	KC	Kitchen Faucet (Life skills Room 1130)	0.00174	No	-	
	400008	16-02-2026	09:45:00	KC 1130B	Flushed	KC	Kitchen Faucet (Life skills Room 1130)	0.0001	No	-	
	400008	16-02-2026	09:50:00	KC 1132A	First Draw	KC	Kitchen Faucet (Life skills Room 1132)	0.00433	No	-	
	400008	16-02-2026	09:55:00	KC 1132B	Flushed	KC	Kitchen Faucet (Life skills Room 1132)	0.00024	No	-	
	400008	16-02-2026	10:00:00	1DW 1030	First Draw	DW	Drinking Fountain	0.0001	No	-	
	400008	16-02-2026	10:05:00	2BF 1030	First Draw	BS	Bottle Filler	0.0001	No	-	
	400008	16-02-2026	10:10:00	2DW 1030	First Draw	DW	Drinking Fountain	0.0001	No	-	
	400008	16-02-2026	10:15:00	1DW 1139	First Draw	DW	Drinking Fountain	0.0001	No	-	
	400008	16-02-2026	10:20:00	2BF 1139	First Draw	BS	Bottle Filler	0.0001	No	-	
	400008	16-02-2026	10:25:00	2DW 1139	First Draw	DW	Drinking Fountain	0.0001	No	-	
	400008	16-02-2026	10:30:00	DW1202	First Draw	DW	Drinking Fountain	0.00065	No	-	
	400008	16-02-2026	10:35:00	DW 1203	First Draw	DW	Drinking Fountain	0.0005	No	-	
	400008	16-02-2026	10:40:00	1DW 2131	First Draw	DW	Drinking Fountain	0.0001	No	-	
	400008	16-02-2026	10:45:00	2BF 2131	First Draw	BS	Bottle Filler (2nd Floor)	0.0001	No	-	
	400008	16-02-2026	10:50:00	2DW 2131	First Draw	DW	Drinking Fountain (2nd Floor)	0.0001	No	-	
	400008	16-02-2026	10:55:00	BF 2108	First Draw	BS	Bottle Filler (2nd Floor)	0.0001	No	-	
	400008	16-02-2026	11:00:00	DW 2108	First Draw	DW	Drinking Fountain (2nd Floor)	0.0001	No	-	
								-	-	-	
	Vedder Middle							-	-	-	
	102082	07-02-2026	07:00:00	KC C593A	First Draw	KC	Kitchen Faucet (Staff Room C593)	0.00031	No	-	
	102082	07-02-2026	07:05:00	KC C593B	Flushed	KC	Kitchen Faucet (Staff Room C593)	0.00046	No	-	
	102082	07-02-2026	07:10:00	BM C593	First Draw	BM	Coffie Maker (Staff Room C593)	0.00028	No	-	
	102082	07-02-2026	07:15:00	NS C60A	First Draw	NS	Health Room (Room C60)	0.0001	No	-	
	102082	07-02-2026	07:20:00	NS C60B	Flushed	NS	Health Room (Room C60)	0.0001	No	-	
	102082	07-02-2026	07:25:00	BF C8	First Draw	BS	Bottle Filler (West Corridor)	0.0001	No	-	
	102082	07-02-2026	07:30:00	DW C8	First Draw	DW	Drinking Fountain (South Corridor)	0.0001	No	-	
	102082	07-02-2026	07:35:00	KC E413A	First Draw	KC	Kitchen Faucet (Room E413)	0.00305	No	-	
	102082	07-02-2026	07:40:00	KC E413B	Flushed	KC	Kitchen Faucet (Room E413)	0.00047	No	-	
	102082	07-02-2026	07:45:00	BF B5	First Draw	BS	Bottle Filler (South Corridor)	0.0001	No	-	
	102082	07-02-2026	07:50:00	DW B5	First Draw	DW	Drinking Fountain (South Corridor)	0.0001	No	-	
	102082	07-02-2026	07:55:00	KC D301A	First Draw	KC	Kitchen Faucet (Room D301A)	0.00034	No	-	
	102082	07-02-2026	08:00:00	KC D301B	Flushed	KC	Kitchen Faucet (Room D301A)	0.00043	No	-	
	102082	07-02-2026	08:05:00	KC B217A	First Draw	KC	Kitchen Faucet (Room B217)	0.00044	No	-	
	102082	07-02-2026	08:10:00	KC B217B	Flushed	KC	Kitchen Faucet (Room B217)	0.00054	No	-	
	102082	07-02-2026	08:15:00	BF B213	First Draw	BS	Bottle Filler (Central Corridor)	0.0001	No	-	
	102082	07-02-2026	08:20:00	DW B213	First Draw	DW	Drinking Fountain (Central Corridor)	0.0001	No	-	
	102082	07-02-2026	08:25:00	BF D4	First Draw	BS	Bottle Filler (Change Room Corridor)	0.0001	No	-	
	102082	07-02-2026	08:30:00	DW D4	First Draw	DW	Drinking Fountain (Change Room Corridor)	0.0001	No	-	
	102082	07-02-2026	08:35:00	KC B207A	First Draw	KC	Kitchen Faucet (Room B207)	0.00058	No	-	
	102082	07-02-2026	08:40:00	KC B207B	Flushed	KC	Kitchen Faucet (Room B207)	0.00043	No	-	
	102082	07-02-2026	08:45:00	1KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.0005	No	-	
	102082	07-02-2026	08:50:00	1KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00034	No	-	
	102082	07-02-2026	08:55:00	2KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00044	No	-	
	102082	07-02-2026	09:00:00	2KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00022	No	-	
	102082	07-02-2026	09:05:00	3KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00031	No	-	
	102082	07-02-2026	09:10:00	3KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.0001	No	-	
	102082	07-02-2026	09:15:00	4KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00027	No	-	
	102082	07-02-2026	09:20:00	4KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00023	No	-	
	102082	07-02-2026	09:25:00	5KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00053	No	-	
	102082	07-02-2026	09:30:00	5KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00025	No	-	
	102082	07-02-2026	09:35:00	6KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00109	No	-	
	102082	07-02-2026	09:40:00	6KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00031	No	-	
	102082	07-02-2026	09:45:00	7KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.0005	No	-	
	102082	07-02-2026	09:50:00	7KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00041	No	-	
	102082	07-02-2026	09:55:00	8KC C502A	First Draw	KC	Kitchen Faucet Foods (Room C502)	0.00304	No	-	
	102082	07-02-2026	10:00:00	8KC C502B	Flushed	KC	Kitchen Faucet Foods (Room C502)	0.00025	No	-	
	102082	07-02-2026	10:05:00	BF D12	First Draw	BS	Bottle Filler (Gym Corridor)	0.0001	No	-	
	102082	07-02-2026	10:10:00	DW D12	First Draw	DW	Drinking Fountain (Gym Corridor)	0.0001	No	-	
	102082	07-02-2026	10:15:00	KC D16A	First Draw	KC	Kitchen Faucet (Canteen Room D16)	0.0001	No	-	
	102082	07-02-2026	10:20:00	KC D16B	First Draw	KC	Kitchen Faucet (Canteen Room D16)	0.0001	No	-	
	102082	07-02-2026	10:25:00	BF C27	First Draw	BS	Bottle Filler (North Corridor - Next to staff room)	0.0001	No	-	
	102082	07-02-2026	10:30:00	DW C27	First Draw	DW	Drinking Fountain (North Corridor - Next to staff room)	0.0001	No	-	
								-	-	-	
	Watson Elementary							-	-	-	
	102030	01-02-2026	14:00:00	KC 25A	First Draw	KC	Staff Room Kitchen Faucet (Room 25)	0.00093	No	-	
	102030	01-02-2026	14:05:00	KC 25B	Flushed	KC	Staff Room Kitchen Faucet (Room 25)	0.00293	No	-	
	102030	01-02-2026	14:10:00	KC 23A	First Draw	KC	Library Office Faucet (Room 23)	0.00349	No	-	
	102030	01-02-2026	14:15:00	KC 23B	Flushed	KC	Library Office Faucet (Room 23)	0.0105	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
	102030	19-07-2026	08:50:00	KC 23B	First Draw	KC	Library Office Faucet (Room 23)	0.00092	No	-	Re Test Results
	102030	01-02-2026	14:20:00	KC 39A	First Draw	KC	Gym Kitchen (Room 39)	0.00282	No	-	
	102030	01-02-2026	14:25:00	KC 39B	Flushed	KC	Gym Kitchen (Room 39)	0.0001	No	-	

102030	01-02-2026	14:30:00	BF 39	First Draw	BS	Bottle Filler (Gym Corridor)	0.0001	No	-	
102030	01-02-2026	14:35:00	DW 39	First Draw	DW	Drinking Fountain (Gym Corridor)	0.0001	No	-	
102030	01-02-2026	14:40:00	1KC 17A	Flushed	KC	K Classroom Faucet (Room 17)	0.00269	No	-	
102030	01-02-2026	14:45:00	1KC 17B	First Draw	KC	K Classroom Faucet (Room 17)	0.0149	Yes	3C	Restrict access to fixture. Post signage or remove.
102030	01-02-2026	14:50:00	2KC 17A	First Draw	KC	K Classroom Faucet (Room 17)	0.00601	Yes	3C	Restrict access to fixture. Post signage or remove.
102030	01-02-2026	14:55:00	2KC 17B	Flushed	KC	K Classroom Faucet (Room 17)	0.00181	No	-	
102030	01-02-2026	15:00:00	1KC 18A	First Draw	KC	K Classroom Faucet (Room 18)	0.00634	Yes	3C	Restrict access to fixture. Post signage or remove.
102030	01-02-2026	15:05:00	1KC 18B	Flushed	KC	K Classroom Faucet (Room 18)	0.004	No	-	
102030	01-02-2026	15:10:00	2KC 18A	First Draw	KC	K Classroom Faucet (Room 18)	0.00816	Yes	3C	Restrict access to fixture. Post signage or remove.
102030	01-02-2026	15:15:00	2KC 18B	Flushed	KC	K Classroom Faucet (Room 18)	0.00047	No	-	
102030	01-02-2026	15:20:00	KC 19A	First Draw	KC	Classroom Faucet (Room 19)	0.002	No	-	
102030	01-02-2026	15:25:00	KC 19B	Flushed	KC	Classroom Faucet (Room 19)	0.00022	No	-	
102030	01-02-2026	15:30:00	KC 20A	First Draw	KC	Classroom Faucet (Room 20)	0.00171	No	-	
102030	01-02-2026	15:35:00	KC 20B	Flushed	KC	Classroom Faucet (Room 20)	0.00469	No	-	
102030	01-02-2026	15:40:00	KC 48A	First Draw	KC	Small Kitchen space Faucet (Room 48)	0.0051	Yes	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
102030	01-02-2026	15:45:00	KC 48B	Flushed	KC	Small Kitchen space Faucet (Room 48)	0.00079	No	-	
102030	19-07-2026	09:00:00	KC 48A	First Draw	KC	Small Kitchen space Faucet (Room 48)	0.00265	No		Re Test Results
102030	01-02-2026	15:50:00	KC 5A	First Draw	KC	Small Kitchen space Faucet (Room 5)	0.00517	Yes	4E	Restrict access to fixture by posting signage or remove completely. Inform management, regional public health office, and water supplier.
102030	19-07-2026	09:10:00	KC 5A	First Draw	KC	Small Kitchen space Faucet (Room 5)	0.00069	No		Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended. Re Test Results
102030	01-02-2026	15:55:00	KC 5B	Flushed	KC	Small Kitchen space Faucet (Room 5)	0.0106	Yes	4E	Restrict access to fixture by posting signage or remove completely. Inform management, regional public health office, and water supplier.
102030	19-07-2026	09:20:00	KC 5B	First Draw	KC	Small Kitchen space Faucet (Room 5)	0.0002	No		Exceedance in flushed sample may indicate corrosive water or presence of upstream lead plumbing. Investigate other outlets in facility for lead. Expert advice in conducting investigation recommended. Re Test Results
102030	01-02-2026	16:00:00	BF 2	First Draw	BS	Bottle Filler (North Corridor)	0.0001	No	-	
102030	01-02-2026	16:05:00	DW 2	First Draw	DW	Drinking Fountain (North Corridor)	0.0001	No	-	
102030	01-02-2026	16:10:00	KC 1P1A	First Draw	KC	Portable #1 Kithcen Facucet	0.00311	No	-	
102030	01-02-2026	16:15:00	KC 1P1B	Flushed	KC	Portable #1 Kithcen Facucet	0.00031	No	-	
102030	01-02-2026	16:20:00	KC 1P2A	First Draw	KC	Portable #1 Kithcen Facucet	0.0136	Yes	3C	Restrict access to fixture. Post signage or remove.
102030	01-02-2026	16:25:00	KC 1P2B	Flushed	KC	Portable #1 Kithcen Facucet	0.00027	No	-	
102030	01-02-2026	16:30:00	KC 2PA	First Draw	KC	Portable #2 Kithcen Facucet	0.00045	No	-	
102030	01-02-2026	16:35:00	KC 2PB	Flushed	KC	Portable #2 Kithcen Facucet	0.00028	No	-	
102030	01-02-2026	16:40:00	BF 8	First Draw	BS	Bottle Filler (East Corridor)	0.0001	No	-	
102030	01-02-2026	16:45:00	DW 8	First Draw	DW	Drinking Fountain (East Corridor)	0.0001	No	-	